

**Title \*** A.W. Wilson CAN-31-0.40  
**Culvert/Bridge Number** CAN-31-0.40  
**Geo Location** 40.032357686242555 -83.35596531501855  
**General Appraisal** 7 Good condition - some minor problems  
**Span Size** 30 inch  
**Culvert Length** 40ft  
**Size of Culvert** 30 inch  
**Type Culvert** Metal

### Conduit

**Level of Inspection** M- MANNED ENTRY INSPECTION  
**Material** 7 GOOD  
**Conduit Alignment** 8 VERY GOOD  
**Shape** 7 GOOD  
**Seams and Joints** 7 GOOD  
**Slab**  
**Abutments**  
**Headwalls**  
**End Structure**

### Channel

**Channel Alignment** 7 Good Silt and gravel buildup restrict half of the channel. Tree or bush growing in the channel.  
**Conduit Waterway Blockage** 7 Good Conduit waterway blockage is less than 5% of the cross-sectional area of the opening. Bank and channel have minor amounts of drift.  
**Scour** 8 Very Good Minor scour holes developing at inlet or outlet. Scour protection placed.  
**Channel Projection** 8 Very Good No noteworthy deficiencies which affect the condition of the channel protection 100 feet upstream. Banks are protected or well vegetated.

### Approaches

**Pavement** 8 Very Good Hairline cracks in pavement. Minor scaling.  
**Guardrail**  
**Embankment** 8 Very Good Minor rutting from drainage; vegetation intact.  
**Comments** Mower damage to end of pipe. No holes in culvert, but light rust and standing water on invert  
**Owner** Rapp, Aaron  
**Completed DateTime** 12/02/2024 12:00:00 AM  
**Request Category** Culvert Inspection  
**Group** Ops-Drainage