

**Title \*** Plain City-Georgesville CAN-7-6.5  
**Culvert/Bridge Number** CAN-7-6.5  
**Geo Location** 40.04767461957833 -83.2620120048523  
**General Appraisal** 8 Very good condition - no problems noted  
**Span Size** 42inch  
**Culvert Length** 40ft  
**Size of Culvert** 42 inch  
**Type Culvert** RCP

### Conduit

**Level of Inspection** X - INPSECTED FROM ENDS OF CONDUIT (NON-ENTRY)  
**Material** 9 EXCELLENT  
**Conduit Alignment** 9 EXCELLENT  
**Shape** 9 EXCELLENT  
**Seams and Joints** 8 VERY GOOD  
**Slab**  
**Abutments**  
**Headwalls**  
**End Structure**

### Channel

**Channel Alignment** 8 Very Good Channel has straight alignment for more than 100 feet upstream. Flow hits protective materials placed to protect conduit material.  
**Conduit Waterway Blockage** 8 Very Good Minor amounts of sediment build-up with no appreciable loss of opening.  
**Scour** 7 Good Minor scour holes developing at inlet or outlet. Top of footings is exposed. Probing indicates soft material in scour hole.  
**Channel Projection** 8 Very Good No noteworthy deficiencies which affect the condition of the channel protection 100 feet upstream. Banks are protected or well vegetated.

### Approaches

**Pavement** 9 Excellent No noticeable defects.  
**Guardrail**  
**Embankment** 9 Excellent No noteworthy deficiencies which affect the condition of the embankment up to 50 feet away from the conduit.  
**Comments** Slight erosion to inlet. Add rip rap  
**Owner** Rapp, Aaron  
**Completed DateTime** 12/12/2024 12:00:00 AM  
**Request Category** Culvert Inspection  
**Group** Ops-Drainage